

Emission Test Certificate

Monday, 23rd March 2015

Supplier: LETObamboo (9 Glenvale Crescent, Mulgrave, VIC 3170)

Sample Description: Bamboo Ply – ‘Narrow Grain, Carbonised Colour’ 19mm (100% bamboo)

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia Green Star Office Interiors v1.1 IEQ-11 & IEQ 12</p>	<p align="center">Bamboo Ply ‘Narrow Grain, Carbonised Colour’ 19mm</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit <0.5mg/m³</p>	<p align="center">Total Volatile Organic Compound Emission Rate: <0.006 mg/m²/hr <0.008mg/m³* (seven days)</p>
<p align="center">Formaldehyde Emission Rate limit <0.1mg/m³</p>	<p align="center">Formaldehyde Emission Rate: <0.005 mg/m²/hr <0.005ppm* (seven days)</p>

*Results for air concentration based on Greenguard Standard Office Model using 29.7m² exposed wall surface area, room volume of 32m³ and ventilation rate of 0.72 hr⁻¹.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150303

Emission Test Certificate

Tuesday February 24th, 2009

Supplier: LETObamboo Pty Ltd (43 Karnak Road, Ashburton Victoria 3147)

Sample Description: Bamboo board

Date Tested: February 2009

Emission Data:

Green Building Council of Australia Green Star Specification	Bamboo Board
Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".	
Office Design V2 IEQ-13 < 0.5 mg/m ² /hr (24 hours) Office Design V3 IEQ-13 < 0.5 mg/m ² /hr (24 hours)	<0.05 mg/m ² /hr (VOC)
Office Interiors V1.1 IEQ-11 < 0.5 mg/m ³ (7 days)	<0.05 mg/m ² /hr (VOC) When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m ³ .
Test Method: EN717-2 "Wood-based Panels - Determination of Formaldehyde Release - Part 2: Formaldehyde Release by the Gas Analysis Method".	
	0.11 mg/m ² /hr (Formaldehyde)

The above results may be considered representative of the bamboo board range supplied by LETObamboo Pty Ltd.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV090209