

Emission Test Certificate

Monday, 23rd March 2015

Supplier: LETObamboo (9 Glenvale Crescent, Mulgrave, VIC 3170)

Sample Description: Bamboo Ply – ‘Narrow Grain, Carbonised Colour’ 19mm (100% bamboo)

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Good Environmental Choice Australia Furniture Fittings and Foam</p>	<p>Bamboo Ply ‘Narrow Grain, Carbonised Colour’ 19mm</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: <0.006 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit <0.1mg/m²/hr</p>	<p>Formaldehyde Emission Rate: <0.005 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150303